

The JCS Industries Model 420-T Ton Mounted Vacuum Regulator is designed for years of safe and reliable service.

This robust design includes a machined front and back body, internal (non-latching) switching mechanism, internal pressure relief vent and a non-metallic inlet valve assembly. The Model 420-T is direct ton container mounted.

The JCS Model 420-T operates as a pressure reducing valve to transfer gas under pressure to gas under vacuum within the chemical feed system.

Installed between the ton container of the chosen gas and the chemical feeder, Model 4200, the Model 420-T will switch from one ton container to the next one in line as soon as the gas in the first ton container is depleted. An internal switchover valve is automatically activated in the event of gas supply failure; the reduction of the vacuum will isolate the regulator diaphragm cavity from pressurized pipe work.



- Rate Range: 1 to 500 PPD
- Shuts off the gas supply in the event of vacuum failure
- Durable components
- Provides an indication of gas supply status
- Does not require an auxiliary pressure reducing valve
- Suitable for chlorine, sulfur dioxide or ammonia gas
- Unit includes an internal switchover valve
- Ton container or yoke mounting capability
- Low part count construction for low maintenance

Range	●	1 to 500 Lbs. Per Day
Electrical	●	110/220 VAC, 50/60 Hz (Heater)
Chemical of Use	●	Cl ₂ , SO ₂ , NH ₃
Mounting Assemblies	●	Ton Container or Yoke
Internal Switchover Valve	●	Yes
Connections	●	Vacuum to injector - 0.375" FNTF
	●	Vent to outside - 0.375" FNTF
Overall Dimensions	●	10" L x 5.125" W x 16" H
Weight	●	11.5 Lbs.

Characteristics

JCS Industries 420-T Ton Mounted Vacuum Regulator will regulate the supply of pressurized chlorine, sulfur dioxide or ammonia gas into a vacuum dosing system at a maximum rate of up to 500PPD.

The regulator consists of: a sealed cavity, diaphragm with opposing return spring, gas inlet valve, vacuum outlet, high pressure vent and vacuum status indicator.

In the event of high vacuum caused by gas supply failure, the regulator will seal off the vacuum from the supply.

In the event of vacuum failure, the return spring safely shuts off the gas supply inlet valve. If gas pressure occurs in the vacuum cavity, it will be vented safely to an external atmosphere.